

DECLARATION OF PERFORMANCE (DoP)



This declaration of performance No 003 is issued under the sole responsibility of the manufacturer.

Manufacturer

KG Groep BV
Spoordijkhof 1
4944 AZ Raamsdonk

Herewith declares that:

Product name : μ -FEP
Product model no : μ -FEP 01
Product description : Fire Alarm & Extinguishing Control Panel
Serial numbers : 101

Notified body:

Nederland B.V (NB 0063) Certification Fire Safety & Security performed tests that comply with Kiwa certification scheme K23003/02 " fixed fire-extinguishing systems based on non-pressurized condensed aerosol generators " of January 17th 2019 for the part on the control unit of the aerosol generators (chapter 5.2 of scheme K23003).

As described in documents,

Declaration : P191200497 **Issue date** : 2020 April 01
Test report : K23003 report configuration test **Issue date** : 2020 April 01
Assessment dates : December 19, 2019 & March 3, 2020

Issues by : KG Groep BV
Date : 01-06-2020
Place : Raamsdonk
Signature : C van Toer

Director